



## NOTES

- All dimensions are in millimeters unless stated otherwise
- Reinforced concrete for all elements should be class 20 (1:2:4) 1 for cement 2 for sand , 4 for aggregate
- The washout pouring to be directed to a chamber away from tank foundation to prevent erosion

## REVISIONS

Date	Suffix	Descriptions

## PROJECT

Water Supply Facilities in Somalia

## Drawing Title

6m HIGH ELEVATED  
CONCRETE WATER  
TANK DETAILS  
Sheet 1 of 2



Somalia Office

Design	Eng Osman Hassan	Date
Checked		Jan, 2020
Approved		
JOB No.Qc/som/2020 ./12		